

**Table 2. Separation distances for aboveground small tanks (1,100 gallons or less) – cont.**

Protected tank (UL 2085) separated from:	Year of FL/CL or other rules*	Minimum separation distance	Your distance
Nearest important building on same property.	2003	5 feet	
Lot line that can be built upon, including opposite side of a public way.	2003	15 feet	
Nearest side of any public way.	2003	5 feet	
Storm drain, surface water or designated wetland.	2003	0	
See separation distances for single-family drinking water well; well on dairy; mineshaft, mine air escape, school, building used for public and combustibles listed under single-walled tank (page 6).	As listed under single-walled tank with or without secondary containment (see above)	As listed under single-walled tank with or without secondary containment (see above)	

\* Rules other than FL/CL rules are specified, with date.

**Figure 2. Aboveground small ( $\leq 1,100$  gallons) UL 142 tank separation distances. All measurements should be considered minimum. (Drawing not to scale.)**

